

ADA Review

Location: _____

County: _____

City: _____

Date: _____

Present: _____

Criteria	NW Corner		SW Corner		SE Corner		NE Corner	
	E-W Ramp	N-S Ramp						
Running Slope on Curb Ramp (8.3% max)								
Cross Slope On Curb Ramp (2% max)								
Cross Slope on Sidewalk (2% max)								
Width of Curb Ramp (min. of 36" wide)								
Transition from Ramp to Roadway Surface (<= 13%)								
Level Landing at Top of Ramp (48" min. depth by width of ramp)								
Level Landing at Push Button (30" x 48")								
Reach Distance(from edge of maneuvering space <=10")								

Location _____ Date _____

Criteria	NW Corner		SW Corner		SE Corner		NE Corner	
	E-W Ramp	N-S Ramp						
Height of Push Button (max of 42" high)								
Crosswalk (Align with ramp)								
Tactile Surface (truncated domes on all post 1/2003 projects)								
Protection From Drop-Off: Handrail (10"+, Pickett style 30+")								
FTP – 49 Sign (Symbol Format)								
Clearance Around Obstructions (32" for not longer than 24")								
Other								
Shoulders: Stabilized/Unstabilized								
Side drains: drop offs, shielded, cleared out?								
All crosswalks should be at least 6 feet wide, 8 and 10 feet preferred.								