

**I-5, SR 501 Ridgefield Interchange
Question and Answer #X - July XX, 2009**

Question	Reference & Page #	Question	Date Received	Response
1	JA1 - JA7, 103 - 109 of 427	I don't see any northings and eastings provided on the alignment/ right of way plans. Perhaps I should be looking somewhere else or I am overlooking them. If this one of these is the case, please direct me to where I can find this information, otherwise, please provide northings and eastings for at a minimum the following locations: 1) beginning of each alignment 2) end of each alignment	6/30/2009, 2:04 PM	Coordinates for Control Points are provided in "CONTROL POINTS DATA" tables. Station and offset information for each control point is provided on the plan sheet next to the symbol for Existing Control Point. See sheet 104 of 427; GPS 50 is in the table and per the Legend - Existing Control Point symbol, GPS 50 is labeled L Sta 384+86.99, 120.01' RT.
2	SQ1 - SQ12, 4 - 15 of 427	Can you provide the schedule of bid items in a text or MS Excel format for transferring into our bid program?	7/1/2009, 8:13 AM	Bid item file is available in electronic format (.txt) by calling (360) 705 7835 and requesting EBIDS diskette for the project. The data can be imported from the diskette using the EBIDS software then imported into your estimating software. See EBIDS instructions at: http://www.wsdot.wa.gov/biz/contaa/electbid/
3	IL sheets	1. Regarding 85 watt QL sign lighters, I don't see anyone listed on the QPL for induction sign lighters. Please advise acceptable manufacturer. 2. Regarding Slip Base light poles, are these to be standard WSDOT flip base light poles, galvanized, and not the decorative poles shown on details for Bridge Mount, Fixed Base, and Wall Mount? 3. Are the decorative light poles to be painted? If so please advise color.	6/30/2009, 11:06 AM	1. Provide a Record of Materials for products that meet the plan specifications. 2. Refer to sheet IL09 for base types and general notes. 3. The color to paint the decorative light poles will be provided in a pending addendum.
4	IL sheets	1. Will it be ok for us to bid Valmont on the deco and standard poles on this project that are equal to the Hapco. 2. Also Valmont on the CCTVpoles. 3. Also will it be ok to bid the Cobrahead (250w mag-reg), and the 85 w induction sign lighters with GE. 4. Also the hi-mast rings and fixtures with GE/Carolina. 5. Will Fouch be acceptable on theService equipment and SS cabinets.	6/30/2009, 3:56 PM	1. No, the poles must be per plans. 2. Valmont poles may be used for the CCTV poles. 3. Cobrahead (250w mag-reg) may be used for the decorative poles, and yes the 85 w induction sign lighters with GE may be used. 4. Yes GE/Carolina hi-mast rings and risers may be used. 5. Yes, if the product meets our specifications.

**I-5, SR 501 Ridgefield Interchange
Question and Answer #X - July XX, 2009**

5	IL sheets	The Valmont poles would be the exact copy of those listed. You have listed .188 allow 6063T6 and exact dimensions on the three profiles; Wall mount; Bridge mount; and Fixed base; I presume those meet AASHTO, but we would furnish calcs on this profile. The fixtures would be exactly as specified.	7/1/2009, 9:41 AM	No, the poles must be per plans.
6				
7				
8				
9				
10				
11				
12				
13				
14				
15				