

**I-5, SR 501 Ridgefield Interchange  
Question and Answer #13 - August 3, 2009**

Question	Reference & Page #	Question	Date Received	Response
1	Special Provisions, Page 241, Lines 13 & 14	The Specials call for Boring to be the primary installation method for the Communication Conduit System. However CDF backfill seems to be required where "Open Trenching" for other Systems is utilized for the Communication Conduit System. Verify this applies to circumstances where the Illumination, Signal or any other System and Data may share the same trench?	August 3, 2:32 PM	CDF would be required to backfill any shared trench; although, it is not anticipated that the communication conduit system will share a trench with other system conduits.