

1 ***(August 6, 2012)***

2 ***Pigmented Cement Concrete***

3 Curing shall be in accordance with Section 5-05.3(13) and be applied to the surface in
4 accordance with the manufacturer's recommendations. If liquid membrane-forming
5 concrete curing compound is used it shall meet the requirements of ASTM C 309 Type
6 1-D.

7
8 The Contractor shall provide a 2 foot by 2 foot sample panel, that has been cured a
9 minimum seven days, showing the color of cement concrete to the Engineer for
10 acceptance before placing any pigmented cement concrete pavement.