

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17

(April 30, 2001)
Bridge Grate Inlet

Steel in grates, angles, and anchors for bridge grate inlets shall conform to Section 9-05.16.

Pipe straps shall conform to ASTM A 36, and shall be galvanized after fabrication in accordance with AASHTO M 111.

Anchor bolts and associated nuts and washers shall conform to Section 9-06.5(1) and shall be galvanized after fabrication in accordance with AASHTO M 232.

Drain pipe stub shall conform to the Section 9-05.1(2) requirements for zinc coated (galvanized) corrugated steel drain pipe.

Elastomeric expansion joint seal glands shall be selected from the approved products listed in the WSDOT Qualified Products List, latest edition, and sized as appropriate for the bridge grate inlet expansion joint shown in the Plans.