

1 (April 6, 2015)  
2 Steel pipe shall conform to ASTM A 53, Grade B, Type E or S, galvanized. The  
3 pipe shall be Schedule 40, except as otherwise specified in the Plans.  
4  
5 PVC pipe shall be any smooth wall, non-perforated, PVC pipe of the diameter and  
6 minimum wall thickness or Schedule specified in the Plans.