

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15

(August 4, 2008)
Repairing Slab Left Exposed After Removing Existing Curb or Sidewalk
The concrete exposed by the removal of the existing curb or sidewalk shall be removed to a depth of 1-inch below finished grade or to the top of the existing roadway deck steel reinforcing bars, whichever is less. The Contractor shall not remove concrete below the top of the existing steel reinforcing bars. The Contractor shall not damage the bond between the existing steel reinforcing bars and the concrete.

After roughening, cleaning and wetting the surface in accordance with Section 6-02.3(12), the Contractor shall place concrete over the surface to the finish grade of the adjacent concrete roadway deck using a modified Class 4000 concrete mix. The maximum aggregate size in the modified Class 4000 concrete mix shall be 3/8 inch. The finished portion of the deck shall have the same texture, slope and grade as that of the existing deck.