

1
2
3
4
5
6
7

(September 8, 2020)

Placing Concrete Headers

The Contractor shall form, cast, and cure, the concrete headers in accordance with Section 6-02.3 and as shown in the Plans. Unless the Plans or Special Provisions specify a different strength, the concrete headers shall have attained a minimum compressive strength of 2,500 psi before the Contractor may allow traffic to pass across the expansion joint.