

1 (September 8, 2020)  
2 The Contractor shall furnish a Class 2 surface finish, as specified in Section 6-  
3 02.3(14)B, on all surfaces of the precast prestressed concrete stay-in-place  
4 panels, except as otherwise noted. The top surface of all panels shall be  
5 textured using a metal tined comb. It shall leave striations in the fresh concrete  
6 ¼-inch deep by at least 1/8-inch wide, spaced at 2 to 3 times the groove width  
7 apart, and oriented perpendicular to the prestressing strand. The timing and  
8 method used shall produce the required texture without displacing larger  
9 particles of aggregate. Areas of mortar buildup more than 1/4 inch above the  
10 top surface of the panel shall be removed.