

1           **(March 6, 2000)**

2           **Bridge Railing Type Chain Link Fence**

3           The post blockouts shall be formed with a steel sleeve of the diameter and  
4           thickness specified in the Plans. The steel sleeve shall be galvanized after  
5           fabrication in accordance with AASHTO M 111. The Contractor shall fill the bottom  
6           portion of the railing post with expanded polystyrene as shown in the Plans.

7  
8           The Contractor shall install the steel posts in the post blockouts as shown in the  
9           Plans. The posts shall be installed vertically, set in position with epoxy resin, and  
10          braced to maintain the vertical position until the epoxy resin hardens.

11  
12          Longitudinal members shall be connected to the steel posts as shown in the Plans.

13  
14          The Contractor shall install the chain link fence fabric in accordance with Section 8-  
15          12.3(1)D, except as otherwise noted. The chain link fence fabric shall be fastened  
16          to the posts and longitudinal members at a maximum spacing of 14 inches.