

1 (April 6, 2015)
2 The Contractor shall not remove the bottom two inches of the existing concrete
3 deck, unless otherwise directed by the Engineer. If the existing concrete bridge
4 deck is punctured by the removal operations, the Contractor shall form the
5 bottom surface prior to placing the patching concrete. The Contractor shall
6 submit the method and materials to be used for such forming as a Type 2E
7 Working Drawing in accordance with Section 6-02.3(16).