1	(August 1, 2005)	
2	Shotcrete Facing	
3	Portland cement shall be Type I or II in accordance with Section 9-01.2(1).	
4		
5	Air entrainment shall be 6.0 percent, <u>+</u> 1.5 percent.	
6		
7	Water for mixing and curing shall be clean and free from substances which may be	
8	injurious to concrete or steel, and shall be free of elements which would cause staining.	
9		
10	Aggregate for shotcrete shall meet the following gradation requirements:	
11		
12	Sieve Size	Percent Passing by Weight
13		
14	1/2 inch	100
15	3/8 inch	90 to 100
16	U.S. No. 4	70 to 85
17	U.S. No. 8	50 to 70

35 to 55

20 to 35

8 to 20

2 to 10 0 to 2.5

U.S. No. 16

U.S. No. 30

U.S. No. 50

U.S. No. 100 U.S. No. 200

18 19

20

21 22