

1 (January 2, 2012)
2 Variations in the bearing layer elevation from that shown in the Plans are
3 anticipated. The Contractor shall have equipment on-site capable of excavating an
4 additional 20 percent of depth below that shown in the Plans.