

1
2
3
4
5
6
7

(April 3, 2006)

Prior to beginning any concrete or grinding work, the Contractor shall submit a plan, for the Engineer's review and approval, outlining the procedures to be used to prevent high pH stormwater or dewatering water from entering surface waters. The plan shall include how the pH of the water will be maintained between pH 6.5 and pH 8.5 prior to being discharged from the project or entering surface waters.