

1
2
3
4

(April 6, 2015)

Steel angles connecting the timber blockout to the existing steel truss members shall conform to either ASTM A 36 or ASTM A 992, and shall be galvanized in accordance with AASHTO M 111.